



Rako RAV232

RS232 Interface

Description

Table of Contents

Table of Contents.....	2
RAKO RS232 Interface Description.....	3
RS232 Interface configuration.....	3
Command Line Interface.....	3
Command Summary.....	4
Command Number Summary.....	5
EEPROM Addresses.....	5
The RAV232PLUS Bi-Directional module.....	6
Command Examples:.....	7

RAKO RS232 Interface Description

RS232 Interface configuration

The Rako® RAV232 RS232 Interface uses the following configuration:

9600/1200 bps, No Parity, 8 Data bits, 1 stop bit

The flow control should be set to Xon/Xoff or None.

Note: The baud rate is selectable using the BAUD command. The default speed is 9600 baud for V1.5.0 and greater or 1200 baud prior to this version.

The Rako® RAV232PLUS Bi-directional RS232 Interface uses the following configuration:

9600 bps, No Parity, 8 Data bits, 1 stop bit

The flow control should be set to Hardware or None.

The Bi-directional RS232 Interface uses the CTS line to indicate it is in a state to receive commands (Hardware flow control). If the CTS line is not connected or the connecting equipment does not implement hardware flow control, care must be taken to either not send commands too quickly or wait for the ">" prompt following a command.

Due to the extra power requirement, the Bi-directional RS232 Interface **MUST** be powered by an external supply of 9 to 15V DC @ 50mA.

Command Line Interface

The interface indicates it is waiting for a command by issuing the ">" character. Characters sent to the interface are echoed. The interface interprets text commands and, where necessary, encodes and transmits the appropriate message via the radio link. The interface is not case sensitive. Each command consists of the following:

[COMMAND] <VALUE>

The command is terminated with a carriage-return character or the '&' character and, depending of the command, has an additional argument. The argument is delimited by one or more white-spaces, tabs or colons. If the Command is valid, the interface responds with:

OK

If the command is invalid, the interface responds with:

Invalid Command!

It is not necessary to enter the full text of the command. A shortened non-ambiguous version can be used. For example the command HOUSE:1 can be shortened to HO:1.

Command Summary

Command	Notes
HOUSE <house_number>	Sets the HOUSE address to <house_number>. The House number must be between 1 and 255. The House number is stored in non-volatile memory.
ROOM [<room_number>]	Sets the ROOM address to <room_number>. The Room number must be between 0 and 255. Room 0 controls all units with the same House address. If <room_number> is omitted, the room is set to 0. The Room address is stored in non-volatile memory.
CHANNEL [<Channel_Number>]	Selects the Channel address. The <channel_number> must be between 0 and 15. Channel 0 controls all channels within the current Room. If <Channel_Number> is omitted the channel is set to 0.
SCENE <scene number>	Sets the scene for the current House/Room/Channel. The <scene number> must be between 1 and 4, which correspond to the buttons on a control panel.
OFF	Turns off the lights in the current House/Room/Channel.
LEVEL <Power_level>	Sets the power level for the current House/Room/Channel. The <power_level> must be between 0 and 255, with 255 representing 100% power.
STORE	Stores the current power level to the current Scene. This will only apply to dimmers addressed by the current House/Room/Channel.
RESET	Resets the microcontroller.
VER	Displays version information
STATUS	Displays current House, Room and Channel in the form: HO:nnn RO:nnn CH:nnn nnn is 3 digit decimal number with leading zeros. nnn is between 0 and 255.
COMMAND [<command_number>]	Issues <command_number> to the lights in the current House/Room/Channel. The <command_number> must be between 0 and 15.
ADDRESS <EEPROM_address>	Sets the EEPROM address within the dimmers. The (<EEPROM_address> must be between 0 and 127.
DATA <EEPROM_data>	Transmits <EEPROM_data> to the address set using the ADDRESS command. The <EEPROM_data> must be between 0 and 255.
NOECHO	Turns off character echoing. This command is only available on the RAV232PLUS Bi-directional RS232 interface. The current echo mode is stored in non-volatile memory.
ECHO	Turns on character echoing. This command is only available on the RAV232PLUS Bi-directional RS232 interface. The current echo mode is stored in non-volatile memory.

Command	Notes
BAUD <BaudRate>	Sets the baud rate of the module. The baud rate must be either 12, for 1200 baud or 96 for 9600 baud. After changing the baud rate the unit must be reset for the changes to take effect. This command is only available on the RAV232 module. The current baud rate is stored in non-volatile memory. Note: if the module is operated at 9600 baud, it may be necessary to use an external supply.

Table 1 – Command Line Interface

Command Number Summary

Using the COMMAND instruction, a literal command can be sent to the addressed controllers. Table 2 details the meanings of the various instructions.

Instruction Number	Instruction	Program mode instruction
0	off	
1	light+	light+
2	light-	light-
3	ps1	Store + Ident
4	ps2	ch+
5	ps3	ch-
6	ps4	
7	program mode	
8	ident	ident
9		
10	low battery	low battery
11	eeprom write	eeprom write
12	level set	level set
13	store	Store
14		exit
15	STOP	STOP

Table 2- Command Instructions

To fade the lights the command light+ or light- must be issued. This fades the lights at the rate determined by the value stored within the dimmer. To stop the lights fading the STOP command needs to be issued.

EEPROM Addresses

Information is stored in the dimmers in non-volatile or EEPROM memory. This memory can be written to using the RS232 interface. The EEPROM consists of 128 bytes of storage, some of which is used internally by the dimmer to remember the current state. ONLY THE ADDRESSES DETAILED BELOW SHOULD BE WRITTEN TO. To write data to the EEPROM area it is first necessary to set the HOUSE,ROOM and CHANNEL address of the dimmer(s). Next, the address should be set using the ADDRESS command and finally, the data should be written using the DATA command.

EEPROM ADDRESS	Action	Notes
1	Scene 1 preset value	
2	Scene 2 preset value	

3	Scene 3 preset value	
4	Scene 4 preset value	
9	Start Mode (After power failure)	0=Off 1-4 = Scene 5=Memory 6-255=Absolute power level
22	Ignore Program Mode	>0= Ignore
23	Ignore Group Commands	>0 = Ignore
24	Ignore House Commands	>0 = Ignore
26	Use Profile	>0 = use profile
34	Scene Fade Rate	0=fast
36	Scene Fade Decay Rate	0=no decay
40	Manual Fade Rate Max	Sets the maximum rate
48	Manual Fade Rate Acceleration	Sets the acceleration to maximum rate
50	Manual Fade Rate Start	Sets the starting fade rate
63-127	Profile Data	Determines the dimmers profile These values should only be changed using the RASOFT software.

Table 3- EEPROM Addresses

Care should be taken when changing values if the channel or house number is set to zero as this will change the values on all the dimmers.

The RAV232PLUS Bi-Directional module

The Rako® RAV232PLUS Bi-directional RS232 interface works as both a transmitter and receiver of Rako coded messages. Using this module it is possible to interface a Rako lighting installation to an external system where the system can both control the lighting and be aware of buttons being pressed on Rako devices.

In addition to accepting the commands defined in Table 1, the Rako® Bi-directional RS232 interface will output received commands in the following format:

<RRR:CC:IN

Where RRR represents the decimal room number from 0-255, CC indicates the channel number 0-15 (0 being 'all channels') and IN indicates the instruction as set out in Table 2- Command Instructions. The string will always be on a separate line, start with a "<" and terminate with a CR LF.

The unit will only output messages for the current house. The house address must first be set using the HOUSE command as described in Table 1.

The following sequence represents a controller in room 4. Note: the text in italics is for explanation and does not appear on the output.

```

<004:00:03          Scene 1 button pressed.
>
<004:00:10          Battery low indication.
>
<004:00:01          Fade up button pressed.
>
<004:00:15          Fade up button released.
>
<004:00:10          Battery low indication.
>

```

Command Examples:

This section details some typical command line examples. The '>' character is issued by the interface as is the 'OK' response. Note that the commands are not case sensitive, shortened versions of the commands and various delimiters can be used.

To set the current house:

```
>HO:1  
OK  
>
```

The house and room address are stored in EEPROM within the RS232 interface and do not require resetting should a power failure occur.

To set the dimmers in room 4 to scene 1

```
>RO:4  
OK  
>CH:0  
OK  
>SC:1  
OK
```

For all the dimmers in room4, set the Start-Mode such that the lights will be at 50% following a power failure.

```
>ro 4  
OK  
>ch 0  
OK  
ADD 9  
OK  
Dat 127  
OK
```